

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Aaron Olver, Secretary

October 7, 2010

WAUSAU CONCRETE CO. COUNTY MATERIALS CO. JIM LUEDEKE 240 HWY 29W PO BOX 130 MARATHON WI 54448 HYDROWORKS, LLC GRAHAM BRYANT 50 21st ST KENILWORTH NJ 07033

Re: Description: STORMWATER TREATMENT DEVICE

Manufacturer: HYDROWORKS, LLC Product Name: HYDROGUARD HG 8

Model Number(s): HG 8

[HYDRODYNAMIC, VORTEX SW TREATMENT SEPARATOR]

Product File No: 20100379

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of NOVEMBER 2015.

This approval is contingent upon compliance with the following stipulation(s):

- Description-- The HYDROGUARD HG-SERIES are hydrodynamic, vortex separator devices designed as vertically-oriented cylinders with dual flow paths. The model number corresponds to the structure's inside diameter in feet.
- Maximum storage capacity: total sediment storage—163 cu ft; oil storage—457 gallons. Maximum flow rates: design flow—3.2 cfs
- Any wastewater or waste materials (e.g. sludge, scum) withdrawn from these systems must be disposed of in accordance with NR 113.
- Prior to installation of this product, plans and specifications must be submitted to the department or to an
  approved agent municipality for review and approval in accordance with s. Comm 82.20 (1) of the Wis. Admin.
  Code. Written approval for the plans and specifications shall be obtained prior to installation of the product.
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product submittal has been reviewed and approved for plumbing treatment standards for subsurface infiltration and irrigation using stormwater as the source, as listed in Table Comm 82.70-1.
- Written approval for the plumbing plans shall be obtained from the department for each installation of this system. If the project is located within the city of Milwaukee, plans may be submitted to either the department or to the city of Milwaukee.
- This product must be installed in a department-approved tank that meets the design criteria for this product, as specified by Hydroworks.
- Labeling: The Hydroworks, Hydroguard series is permanently labeled as follows (as listed in HG Series Labeling Details, ver. 1.0):
  - 1) The Hydroworks logo and coding numbers are painted on the mono-base (each manhole riser); the coding indicates the project, structure ID/location and stacking sequence for installation purposes. Labels generally are painted twice on the product at 180 degrees apart.
  - 2) The model number is not painted on either product, but the model series corresponds to the diameter of the mono-base; for example, the Hydroguard HG-4 has a 4-ft. diameter.
- Inspection and maintenance of each installation of this product shall be conducted when the TSS/sediment reaches 30 inches or when floatables or oils cover > 50% surface. Anticipated maintenance intervals are 1 to 2 years.

SBD-10564-E (N.10/97) File Ref: 10037903.DOC

WAUSAU CONCRETE CO.

Page 2

October 7, 2010

Product File No: 20100379

- Installation-- Installation of this product must be in accordance with the manufacturer's printed installation instructions. A copy of the manufacturer's installation instructions must be given to the property owner, installer and submitted along with other information required by the governing agency for the installation.
- This product submittal has been reviewed and approved for plumbing treatment standards for subsurface infiltration and irrigation using stormwater as the source, as listed in Table Comm 82.70-1.
   Each site-specific installation shall be submitted for review and include acceptable methods, modeling, or analysis to predict efficiency for TSS and oil & grease removal.
- Note: Information on how to access SLAMM and P8 and the average annual rainfall files for five locations in the state, as published periodically by the department, is available at: http://dnr.wi.gov/runoff/models/index.htm
  - or by contacting the WDNR storm water management program at (608) 267-7694.
- Pollutant loading models such as DETPOND, SLAMM, P8 or equivalent methodology may be used to
  evaluate the efficiency of the design in reducing total suspended solids. Information on how to access
  these models is available at: <a href="http://dnr.wi.gov/runoff/models/index.htm">http://dnr.wi.gov/runoff/models/index.htm</a>
  or by contacting the WDNR storm water management program at (608) 267-7694.
- This manhole riser/catch basin must be designed to withstand the loads to which it will be subjected. All manhole covers terminating above grade must have effective locking devices.
- Installation-- The installation of this product shall maintain a working emergency overflow or outlet pipe. Each installation shall conform to Hydroguard Installation Instructions (ver. 1.2).
- Maintenance: The Hydroworks, Hydroguard series maintenance is as follows (as listed in Hydroworks Hydroguard Technical Manual, ver. 2.2):
  - 1) In addition to a 12-month maintenance interval for stabilized sites, inspection is provided via an access cover where TSS depth measurements maybe made after each large storm event.
  - 2) Visual inspection of floatables may be made via the access cover.
  - 3) For parking lots and stabilized sites, a 24-month interval is recommended for grease and oil removal.
  - 4) TSS and trash removal may be made using a vactor truck.
- These devices must be installed, maintained and serviced as directed by the manufacturer to perform as advertised.

This approval supersedes the approval issued on 11/18/2005 under product file number 20050830.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20050830/

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST Engineering Consultant--Plumbing Products Review Commerce; Safety & Buildings Div. PO Box 2658 201 W Washington Ave. Madison WI 53703-2658

Phone: 608-266-0955; Fax: 608-283-7456

E-mail: Jean.MacCubbin@WI.GOV